

Facility Summary in POWDER RIVER County in the City of BIDDLE

Location: CROSS RANCH MERC
MT HIGHWAY 59
BIDDLE, MT 59314 POWDER RIVER

Sys Fac ID: 38-01493
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 8/10/2017

Contact: Nathan Rumph, (406) 427-5447

Owners/Operators: Nathan Rumph, Owner (406)-427-5447 PO BOX 396
BIDDLE MT 59314-0396
Connie Rumph, UST Class A Operator
Connie Rumph, UST Class B Operator
Connie Rumph, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	25	9/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
783			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			Auto Stik II , EBW		
8	25	9/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
784			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			Auto Stik II , EBW		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: THE CORNER STORE
106 W HOLT ST
BROADUS, MT 59317 POWDER RIVER
Contact: Milton Amsden, (406) 436-2666

Sys Fac ID: 38-00126
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Milton L Amsden, Owner (406)-436-2924 DBA CORNER STORE
BOX 1
BROADUS MT 59317
Milton L Amsden, UST Class A Operator
Milton L Amsden, UST Class B Operator
Milton L Amsden, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
933			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
934			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
935			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
4	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
936			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: COUNTY SHOP MAINTENANCE YARD
3 COUNTY SHOP ROAD
BROADUS, MT 59317 POWDER RIVER

Sys Fac ID: 38-00548

Last Inspected On: 9/18/2014

Operating Permit Renewal Date: 11/26/2017

Contact: Mark Larue, (406) 436-2248

Owners/Operators: Powder River County, Owner (406)-436-2361 PO BOX 200
BROADUS MT 59317-0200

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	24	6/17/1991	Cathodically Protected Steel	Steel	High Level Alarm
1807			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/18/2014	Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: ALDERMAN OIL CO
601 S PARK AVE PO BOX 120
BROADUS, MT 59317 POWDER RIVER
Contact: Gary Alderman, (406) 436-2898

Sys Fac ID: 38-03951
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Alderman Oil Co, Owner (406)-436-2898 PO BOX 120
BROADUS MT 59317-0120
Gary Alderman, UST Class A Operator
Theresa Alderman, UST Class A Operator
Gary Alderman, UST Class B Operator
Theresa Alderman, UST Class B Operator
Cheryl McDowell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	22	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
359			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
5	22	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
360			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	22	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
361			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: ALDERMAN OIL CO
601 S PARK AVE PO BOX 120
BROADUS, MT 59317 POWDER RIVER
Contact: Gary Alderman, (406) 436-2898

Sys Fac ID: 38-03951
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 11/6/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	17	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
362			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
8	17	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
363			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
9	17	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
364			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		